

ANNEXURE-III

GENERAL DESIGN PARAMETERS FOR INLET EFFLUENT QUALITY

Sl.No	Parameter	Range
1	pH	5-10
2	COD	1,50,000 mg/l
3	BOD	50,000 mg/l

A. James

**SENIOR ENVIRONMENTAL OFFICER
Waste Management Cell**