


Ph : 080-23238458
Fax : 080-23238300



Email: centrallab@kspcb.gov.in
Website : <http://kspcb.gov.in>

**KARNATAKA STATE POLLUTION CONTROL BOARD
CENTRAL ENVIRONMENTAL LABORATORY**

Legal 42(3)/87,E(P)ACT,1986RECOGNISED ENVIRONMENTAL LABORATORY
AN ISO/IEC 17025:2005 (NABL) ACCREDITED LABORATORY &
IS 18001:2007 CERTIFIED LABORATORY


ಕ.ರಾ.ಮಾ.ನಿ.ಮಂ., ನಿಸರ್ಗಭವನ,
೭ ನೇ 'ಡಿ'ಮುಖ್ಯರಸ್ತೆ, ತಿಮ್ಮಯ್ಯ ರಸ್ತೆ, ಶಿವನಗರ,
ಬೆಂಗಳೂರು-೫೬೦೦೦೧
K.S.P.C.B., "Nisarga Bhavan"
7th D Cross, Thimmaiah Road,
Shivanagar,
Bangalore - 560079

ANALYSIS REPORT

Date: 18.09.2018

NAME OF THE INDUSTRY :	M/s, Pai & Pai Chemicals (I) Private Ltd., Organic Plant, No. 25-D, Kumbalgodu Industrial Area, Mysore Road, Bengaluru.	Page 1 of 1			
SAMPLE COLLECTED BY :	RO: Rajarajeshwari nagar	DATE OF COMMENCEMENT OF TEST: 05.09.2018			
DATE OF COLLECTION :	04.09.2018	DATE OF COMPLETION OF TEST: 10.09.2018			
DATE OF RECEIPT :	05.09.2018	SAMPLE REPORT NO: R-I-1097			
PARTICULARS :	Final treated ETP sample	SAMPLE NO : R-I-1097			
Sl No.	Parameters	Unit	Standard	Result	Test Method
1.	pH @ 25°C	-	5.5-9.0	7.0	IS:3025 (Part 11):1983 Reaffirmed 2002
2.	Biochemical Oxygen Demand (3 days @ 27 °C)	mg/L	100	71	IS 3025 (Part 44):1993 Reaffirmed 2009
3.	Total Suspended solids	mg/L	200	22	IS:3025 (Part 17)-1984 Reaffirmed 2012
4.	Total Dissolved Solids	mg/L	2100	2024	IS:3025 (Part 16):1984 Reaffirmed 2006
5.	Chloride as Cl	mg/L	600	363	IS:3025 (Part 32)-1988 Reaffirmed 2003
6.	Sulphate as SO ₄	mg/L	1000	153	IS:3025 (Part 24):1986 Reaffirmed 2003
7.	Boron as B	mg/L	2.0	0.89	APHA (22 nd Edition): 2012:4500B-B;
8.	Percent Sodium *	%	60	68	By Calculation
9.	Oil & grease	mg/L	10	< 1.0	APHA 22 nd Edition.2012;5520B;
INFERENCE		Non Conforms to prescribed standards.			

- Note: 1. The above results pertain only to the sample tested.
2. The report shall not be reproduced without the written approval of Head of the laboratory.
3. Samples will be stored for a period of 15 days from the date of dispatch of report.
4. *- Tests are not under the scope of NABL Accreditation.


Authorized Signatory (Chemical)
P.Sarathy
Scientific Officer

-----End of Report-----

